






P.O. Box 3365 South El Monte, CA 91733 626.444.0541 Fax 626.444.3887 www.Afcon.org

511


CPVC - COPPER SIDE MOUNT HANGER



Side View - For
Drawings Below



Hanger - Wood Stud



Hanger - Metal Stud

SIZE - 3/4" thru 2" pipe.

MATERIAL - Carbon Steel.

FINISH - Mil. Galvanized.

LISTING/APPROVAL -

 **203 - EX 4231, EX 2551**

FUNCTION - Hanger on CPVC and Copper pipe.

INSTALLATION - Per NFPA 13, 13R, 13D and CPVC manufacturers instructions on top or bottom of beam.

Space by pipe type

SPECIAL NOTE: When installing on CPVC sprinkler system pipe:

Verify that all assembly components are cleaned of any surface oil.

FASTENERS - UL Listed per NFPA 13.

in **WOOD:**

3/4" - 2" CPVC pipe - #905 screw - no pre-drill.

3/4" - 2" Copper pipe - #905 screw - no pre-drill.

in **STEEL** - min. 18 GA.

3/4" - 2" CPVC pipe - 1/4" or #14 Tek Screw.

3/4" - 2" Copper pipe - 1/4" or #14 Tek Screw.

FEATURES

* Offset edge eliminates abrasion.

* Retainer dimples secure hanger to pipe during installation.

* Required *AFCON* #905 screw has 5/16" hex head - included.

ORDERING - Part # and pipe size.

Specific *AFCON* products are exclusively designed to be compatible **ONLY** with other *AFCON* products including parts and fasteners, resulting in a listed sway brace, restrainer or hanger assembly. **Be advised** the following warranty restriction will apply. **DISCLAIMER** - *AFCON* will **NOT** warrant against the failure of its products when used in combination with other products, parts or systems not manufactured or sold by *AFCON*. *AFCON* shall **NOT** be liable under any circumstances whatsoever for any direct or indirect, incidental or consequential damages of any kind, including but not limited to loss of business or profit, when non-*AFCON* products have been, or are used.

