





P.O. Box 3365 South El Monte, CA 91733 626.444.0541 Fax 626.444.3887 www.Afcon.org

001/020

SWAY BRACE FITTING - MODEL E



SIZE - SYSTEM PIPE - Nominal Pipe Size:

Steel 1" thru 8" Schedule 7 thru 40

SIZE - BRACE PIPE: 1" and 1 1/4" Schedule 40.

MATERIAL - Carbon Steel or S.S. (Type 304).

FINISH - Plain or E.G.

PATENT - No. 3,570,794

LISTING/APPROVAL -



203A-EX 2625

Listed only for use with other AFCON bracing products.

FM Approved

OSHPD OPA-0601-07 See Website.

FUNCTION - Lateral sway brace fitting of an AFCON sway brace assembly. Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions.

INSTALLATION - Per NFPA 13. **Load rating - see chart.**

ASSEMBLY - Place Model E over system pipe, then insert brace pipe through rod bend and under channel bracket, leaving minimum 1" extension. Tighten hex nuts until gage spring lays flat or torque to 65 in.-lbs.

FEATURES

* Visual inspection, verifies proper installation.

ORDERING - Part #, pipe size to be braced, brace pipe size and finish.

Horizontal Load Ratings			
Size	FM Sch. 7-40	UL Sch. 10-40	UL Sch. 7
1 - 2	1300	2015	655
2 1/2 - 4	1500	2015	655
5 - 6	1500	2015	1500
8	1500	2015	---

Specific AFCON products are exclusively designed to be compatible ONLY with other AFCON products including parts and fasteners, resulting in a listed sway brace, restrainer or hanger assembly. Be advised the following warranty restriction will apply. **DISCLAIMER - AFCON will NOT warrant against the failure of its products when used in combination with other products, parts or systems not manufactured or sold by AFCON. AFCON shall NOT be liable under any circumstances whatsoever for any direct or indirect, incidental or consequential damages of any kind, including but not limited to loss of business or profit, when non-AFCON products have been, or are used.**

