






P.O. Box 3365 South El Monte, CA 91733 626.444.0541 Fax 626.444.3887 www.Afcon.org

077

ATTACHMENT FITTING LOCKING



SIZE - BRACE PIPE - 1" and 1 1/4" Sch. 40
MATERIAL - Carbon Steel, Ductile Iron or S.S. (Type 304).
FINISH - Plain or E.G.
LISTING/APPROVAL -



Horizontal Load Ratings		
Base Material	FM	UL
Ductile	1500	2015
Steel	---	2015

FUNCTION - Structure attachment fitting of an *AFCON* sway brace assembly.
 Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions.

INSTALLATION - Per these instructions including NFPA 13 and 13R.

Load rating - see chart.

The required type, number and size of fasteners used to structure attachment fitting shall be in accordance with NFPA 13.

ASSEMBLY

- Combine with proper *AFCON* components.
- Insert brace pipe into fitting against the pivot bolt.
- Tighten set bolt until head contacts bracket.
- Torque pivot bolt to 40 ft. lbs.

FEATURES

- * Swivel allows attachment at any angle.
- * Visual inspection, verifies proper installation.
- * Larger fastener hole available.- Consult factory.

ORDERING - Part #, pipe size and finish.

Specific *AFCON* products are exclusively designed to be compatible ONLY with other *AFCON* products including parts and fasteners, resulting in a listed sway brace, restrainer or hanger assembly. Be advised the following warranty restriction will apply. **DISCLAIMER** - *AFCON* will NOT warrant against the failure of its products when used in combination with other products, parts or systems not manufactured or sold by *AFCON*. *AFCON* shall NOT be liable under any circumstances whatsoever for any direct or indirect, incidental or consequential damages of any kind, including but not limited to loss of business or profit, when non-*AFCON* products have been, or are used.