






P.O. Box 3365 South El Monte, CA 91733 626.444.0541 Fax 626.444.3887 www.Afcon.org

088

SWAY BRACE ADAPTER



SIZE - SYSTEM PIPE: 4" max.
MATERIAL - Carbon Steel
FINISH - Plain or E.G.
LISTING/APPROVAL -

 **203A-EX 2625, 203-EX 2551**
Listed only for use with other AFCON bracing products.
OSHPD OPA-0601 See Website.

FUNCTION - Sway brace adapter for an *AFCON* sway brace assembly.
Designed to attach through wood on a steel structural member.
Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions.
Additionally listed as an 8" hanger attachment.

INSTALLATION - Per NFPA 13 and these instructions.
Load rating - see chart.
Combine with proper *AFCON* components.
The structural members design will dictate specific attachment criteria.
Finger tight plus 1 turn or 20 ft. lbs.

ASSEMBLY - See drawing.
Engage tight to underside of steel top chord, drill nominal 2 1/2 x 5 wood nailer, install 1/2" stud thru brackets engaging *AFCON* sway brace fitting 070 series.
* Stud and fasteners furnished by customer.

FEATURES
* Furnished with 1/2" rod hole.
ORDERING - Part #, Finish. Specify custom hole size.

Horizontal Load Ratings	UL
Parallel 30° thru 90° - 1/2" Stud	1400
Perpendicular 30° thru 90° - 1/2" Stud	1400

Specific *AFCON* products are exclusively designed to be compatible **ONLY** with other *AFCON* products including parts and fasteners, resulting in a listed sway brace, restrainer or hanger assembly. **Be advised** the following warranty restriction will apply. **DISCLAIMER** - *AFCON* will **NOT** warrant against the failure of its products when used in combination with other products, parts or systems not manufactured or sold by *AFCON*. *AFCON* shall **NOT** be liable under any circumstances whatsoever for any direct or indirect, incidental or consequential damages of any kind, including but not limited to loss of business or profit, when non-*AFCON* products have been, or are used.

